

Grid Interconnection Studies of Bagasse Based Co-generation Power Plants in Pakistan

Case Study

Presented by Hassan Jafar Zaidi

CEO, Power Planners International (Pvt.) Ltd. Pakistan

at

SAARC Workshop on Application of on-grid Biogas Technologies

16-17 May, 2016

Intercontinental Hotel Kabul, Afghanistan

Bagasse Potential in Pakistan

- Bagasse is a fibrous Captive Biomass
- An excellent Raw Material for power generation
- Existing 81 sugar mills with an annual capacity of about six million tons sugar
- The industry crushes about 30 - 40 million tons of sugar cane that yields about 12 million tons of bagasse as an industrial waste
- It has a potential of generating 2000 MW electricity

Bagasse Potential in Pakistan



Interconnection Studies Completed or Ongoing by PPI

- Bagasse Based

Sr. No.	Name of Sugar Mill	Installed Capacity (MW)		Spillover to National Grid (MW)	
		Summer	Winter	Summer	Winter
1	Fatimah Sugar Mills	120		107	88
2	Alliance Sugar Mill	30		19	
3	Al-Moiz (Layyah Sugar Mill)	25	20	16	12
4	Al-Moiz (Mianwali Sugar Mill)	20	15	16	10
5	Chanar Sugar Mill	22		19.3	
6	Chiniot Suagr Mill	60		54	
7	Etihad Sugar Mill	74		67	
8	Jamal-din-Wali (JDW-II-USM)	26		26	
9	Jamal-din-Wali (JDW-III-GSM)	26		26	
10	Kamalia Sugar Mill	17		12	
11	RYK Sugar Mill - Unit I	30		19	
12	RYK Sugar Mill - Unit II	36		33	
13	Shahtaj Sugar Mill	32		15	
14	Hamza Sugar Mills	32		15	
15	Shiekhoo Sugar Mill, Muzaffargarh	6		6	
16	Indus Sugar Mills	25		25	
17	Mirpur Khas Sugar Mills	20		20	
18	Tandlianwala Sugar Mills	74		74	
Total		675		649.3	


Interconnection Studies Completed or Ongoing by PPI

- Agricultural Biomass**


Sr. No.	Name of Biomass Mill	Installed Capacity (MW)
1	Lumen Energia near Jhang	12
2	Masood Textile Mills Limited Faisalabad	12
3	Shakarganj Energy near Bhone, Jhang	20
4	SSJD, Gorchanni, Mirpurkhas	12
Total		56

30 MW Power Plant by Alliance Sugar Mills Interconnection Scheme

132 kV Network Near Dharki With Alliance PP, Year January 2016




25 MW Power Plant by Layyah Sugar Mills Interconnection Scheme




20 MW Power Plant by Almoiz Sugar Mills Interconnection Scheme

132 kV Network Near Piplan
With Al-Moiz Thermal Power Plant-II, Year 2017




22 MW Power Plant by Chanar Sugar Mills Interconnection Scheme



60 MW Power Plant by Chiniot Sugar Mills Interconnection Scheme

**132 kV Network Near Bhowana
With Chiniot Thermal PP, January 2016**




Legend

220 kV	
132 kV	
Proposed 132 kV	
Proposed 11 kV	


Sketch-2			
Interconnection Study of Chiniot Thermal PP			
Power Planners International			
DATE	SHEET	SCALE	REV
2013	1	Chiniot Sketch-2.DWG	

74 MW Power Plant by Etihad Sugar Mills Interconnection Scheme



26 MW Power Plant by Jamaldin Wali (JDW) Sugar Mills Interconnection Scheme

132 kV Network Near Ghotki
With JDW-III GSM PP, 2014




Legend

132kV	—
66kV	—
Proposed 132kV	—

Sketch-2			
Interconnection Study of JDW-III GSM PP			
Power Planners International			
DATE	SHEET	PROJECT	REV
2013	1	JDW Sketch-2.DWG	

26 MW Power Plant by Jamaldin Wali (JDW) Sugar Mills Interconnection Scheme

132 kV Network Near Sadiqabad With JDW-II USM Co-Generation PP, January 2014




Legend
 220 kV ———
 132 kV ———
 Proposed 132 kV ———

Sketch-2			
Interconnection Study of JDW-II USM PP			
Power Planners International			
DATE	SHEET	NO. OF SHEETS	REV
2013	1	JDW Sketch-2.DWG	


17 MW Power Plant by Kamalia Sugar Mills Interconnection Scheme

**Network Around Proposed Site of Kamalia Mills PP
(with Kamalia Mills-PP, Year 2016)**


Option - I




RYK Sugar Mills 30 MW (Unit-1) and 36 MW (Unit-2) Interconnection Scheme




32 MW Power Plant by Shahtaj Sugar Mills Interconnection Scheme




6 MW Power Plant by Shekhoo Sugar Mills Interconnection Scheme



12 MW Biomass Power Plant by Lumen Energia Interconnection Scheme



20 MW Biomass Power Plant by Shakargunj Energy Interconnection Scheme



Fundamental Studies required for Interconnection Study

- PPI is conducting Interconnection Study constituting following main components
- Load Flow study
 - Steady State performance
 - Adequacy of loading limits of circuits affected due to interconnection i.e no overloading on any line/Transformer
 - Voltage profile to be within the Grid Code $\pm 5\%$ off-nominal
 - Contingency Analysis
 - No overloading on any line/Trafo under one line out condition (N-1 Criteria of Grid Code)
 - Voltage Profile to be within $\pm 10\%$ off-nominal

Fundamental Studies required for Interconnection Study

- Short Circuit Study
 - 3-Phase and Single-Phase fault currents are calculated:
 - To determine the ratings of the equipment to be installed at the switching station of the power plant i.e. breakers, Isolators, CTs, PTs and other switchgear
 - To confirm if the fault levels on the substations in the vicinity of the new power plant are within the ratings of the equipment already installed there because fault current contributions from the new power plant would increase the fault levels on its neighbouring substations
 - To carry out protection coordination and relay settings of at the proposed power plant and also on the neighboring substations if so required

Fundamental Studies required for Interconnection Study

- Transient Stability Study
- If the system stays stable and does not lose synchronism after any severe fault happens on the system such as 3-Ph or 1-Ph faults by monitoring
 - Rotor angles of generators of the entire system must stay in synchronism
 - Power swings on transmission lines must damp rapidly
 - Voltage on bus bars recover soonest to the acceptable level i.e. within 2-3 seconds
 - Frequency recover after any dips or over-frequency event

Bagasse Power Plant



Bagasse/ Biomass Power Plants



Bagasse/ Biomass Power Plants



Bagasse/ Biomass Power Plants



***Thank You
for Your Attention***